

**FLOYD TOWN COUNCIL MEETING
W. SKIP BISHOP JR., TOWN HALL
February 9, 2013
6:30 P.M.
MINUTES**

MEETING CALL TO ORDER –

- ◆ Motion by Councilman Patton, seconded by Councilman Miller and passed. The Floyd Town Council reconvened the recessed February 7, 2013 Town Council meeting. The purpose to of the reconvened meeting is to walk and evaluate the TEA-21 Phase 1 Construction.

ROLL CALL – Mayor Griffin, Vice-Mayor Miller, Councilwoman Bingham, and Councilman Patton were present. Councilman Turner was absent.

Observations made by the Town Council:

1. Road Pavement is collapsing at the storm drain on Rt. 221 (E. Main Street)
2. Rusted fence at the tail end (Rt. 221) – should be painted black.
3. Concrete blob (spill) at the trail end (Rt. 221)
4. Mortar turning white on new brick columns at trail end.
5. Benches in pocket park – rough wood/splintering on back, benches are too narrow and stain already wearing, not sturdy looking.
6. Pocket Park – needs straw/landscaping – Erosion sediment control needed around drain in pocket park. Mud washing into drain now.
7. Sidewalk looks good.
8. Landscaping on Church side is rocky, needs filling in and topsoil.
9. Snapped limb in cypress near Old Church Gallery.
10. Concrete different color near corner at Rick Lewis Way.
11. Exposed conduit (security cameras?) sticking out of ground at corner at Rick Lewis Way.
12. Landscaping needed inside and outside corner at Rick Lewis Way.
13. Water meter in depression in middle of walkway at corner of Rick Lewis Way. Tripping hazard.
14. Raised water meters sticking out of ground to either side of walkway at corner of Rick Lewis Way.
15. Privacy fence at Wagners – large gaps at bottom – needs to be filled in.
16. Stone wall next to walkway at end of privacy fence needs to be extended.
17. Filling needed between stone wall and privacy fence. Currently catching trash.
18. Hotel Floyd dumpster next to trail – to be moved by Hotel Floyd in the future.
19. What is the plan for landscaping between trail and Hotel Floyd parking lot?
20. Stone wall – some pieces appear to have been cracked or broken and repaired/
21. Stone wall - Colors don't match – some reddish, other gray. Doesn't look uniform.
22. Gap in stone wall on Hotel Floyd side below switchback.
23. Stone wall at switchback doesn't match (mortar is gray color) portion extending down along Hotel Floyd parking lot and Wagner property. (Stack; red and gray color).
24. Inferior blocks along switchbacks – doesn't meet up with seal.
25. Plaza and modern benches on connection from switchback to Hotel Floyd sidewalk?
26. Handrails on stairs at switchback extremely loos. Unacceptable.
27. Exposed electrical conduit below wall between Wagners and fence.
28. Wooden slat fence between trailers and Town Parking Lot – needs to be extended 2-3 more panels to meet what Todd Christianson recommended with end trellis.
29. Main question/concern – Landscaping next to walkway.

30. Wire sticking out of ground next to cemetery fence near corner of Town lot.
31. What is the story behind the benches next to the switchback? Should there be a wall at the east end of the “plaza”?

Notes for Town Manager:

1. Finish back of Crooked Road Kiosk – corkboard?
2. Bicycle rack at Town Lot.
3. Replace grate beneath Crooked Road Kiosk with one made in USA.

ADJOURNMENT

- ◆ Motion by Councilman Miller, seconded by Councilman Patton and passed. The February 9, 2013 reconvened meeting of the Floyd Town Council adjourned.

William R. Griffin, Mayor

Karen Y. Hodges, Clerk